

## Quality Requirements for Engine Coolant (Fresh Water)

Property/feature	Features	Unit
Type of water	preferably distilled water or freshwater, free from foreign matter. Not be used: Sea water, brackish water, river water, brines, industrial waste water and rain water	-
Total hardness	max. 10	°dH
pH-value	6.5 - 8	-
Chloride ion content	max. 50	mg/l (= ppm)